



# DANGEROUS GOODS SAFETY REGULATION OF LP GAS STORAGE

Do you store LP Gas...



Cylinders in a quantity of less than 120 litres  
(maximum size 36 litres) at a residence or 432 litres  
(maximum size 108 litres) at a factory or workshop?

YES

## MINOR STORAGE

Comply with Section 2 of AS 1596



Cylinders in a quantity less than 500 litres at a  
commercial site?

YES

## SMALL QUANTITY DANGEROUS GOODS LOCATION

Comply with DG storage regulations  
[rr. 123 - 133]; see AS 1596 for guidance



In a quantity between 500 litres and 5,000 litres at  
a commercial site?

YES

## PLACARDING QUANTITY

DG storage regulations apply; apply risk  
assessment and risk control measures



In a quantity exceeding 5,000 litres at a commercial  
site?

YES

## MANIFEST QUANTITY

DG storage regulations apply; DG Site  
Licence required; apply risk assessment  
and risk control measures