




Regulation of **LP Gas** storage

Do you store LP Gas?



Cylinders in a quantity of less than 120 litres (maximum size 36 litres) at a residence or 432 litres (maximum size 108 litres) at a factory or workshop?

Yes →

Minor storage

Comply with Section 2 of AS 1596



Cylinders in a quantity less than 500 litres at a commercial site?

Yes →

Small quantity dangerous goods location

Comply with DG storage regulations (rr. 123 - 133); see AS 1596 for guidance



In a quantity between 500 litres and 5,000 litres at a commercial site?

Yes →

Placarding quantity

DG storage regulations apply; apply risk control measures



In a quantity exceeding 5,000 litres at a commercial site?

Yes →

Manifest quantity

DG storage regulations apply; DG Site Licence required; apply risk assessment and risk control measures

